



RADON SCREENING:

Date:

Property:

Findings:

Passed - Within EPA guidelines.

0.5 pCi/L measured after 48 hours continuous monitoring with an EPA approved photodiode radon sensing system. (EPA recommend levels above 4.0 pCi/L be corrected)

Please note that radon results are not guaranteed as these readings can vary with season, weather, over time and with test conditions being altered or tampered. EPA recommends testing every two years. NEHA #106438RT.

Summary and Recommendations:

No action required.

Inspector

Jason Donofrio

Serial # :102730GW-212426027

Data in pCi/l
Time Interval 1 Hr

1.3	0.3	0.3
0.3	0.6	1.3
0.0	0.3	0.0
0.0	0.0	0.6

0.0	0.0	0.3
0.3	0.6	0.0
0.3	0.6	0.3
1.0	0.0	0.3

0.6	0.3	0.6
0.6	0.0	0.3
0.6	0.6	0.3
1.0	0.3	1.0

0.6	1.0	0.0
0.3	0.0	1.0
0.3	0.6	0.3
1.0	1.3	1.6

1.3	2.0	0.6
0.0	0.3	0.3

Overall Avg.= 0.5

EPA Protocol Avg.= 0.5

0 4 8

Donofrio & Associates, LLC



Follow us for helpful tips and updates